

Performance mail from Hindalco Renukoot.

Pl. see the RPD performance report of Blr.# 3 at Co. Gen, Renukoot, after installing new APH in trailing mail for your reference & further analysis.

Best Regards,

N.K.Srivastava
Head- Mechanical Maintenance
Boiler & Co-Generation
HIL , Renukoot, Sonebhadra
Phone: 3119 (O), 3166 (R)
Mob# +918808036161

----- Forwarded by Navnit Srivastava/Boiler/Hindalco/ABG on 18-03-2013 15:12 -----

"T K Singh" <tarun.singh@adityabirla.com>

To <chandra.ssingh@adityabirla.com>,
<navnit.srivastava@adityabirla.com>,
<yogendra.n.singh@adityabirla.com>

05-03-2013 18:13

cc <rk Gupta.rpd@adityabirla.com>

Subject P.G Test report of Co-gen Boiler # 3 After Survey

Please find attached herewith performance test report of Boiler #3 after survey.

There is reduction in flue gas temp. of about 10 deg.c. & overall improvement in boiler efficiency is about 1.6 % wrt before s/d

submitted for kind perusal

Best Regards,
Tarun Kant Singh